



Material

Base Plate - steel, hot dipped galvanized
 Tube - steel, 1.500" O.D. electro-galvannealed
 Base weld covered with protective paint
 Pedestal axial load test per CISCA recommended testing
 procdures for access flooring.

Note:
 All dimensions are nominal.
 To prevent zinc whiskers
 Global IFS does not use
 electro-galvanized finishes
 on any of its access flooring
 products.