



Material

Base Plate - steel, electro-galvannealed  
 Tube - steel, 7/8" square hot dipped galvanized  
 Pedestal axial load test per CISCA recommended testing  
 procedures for access flooring.

**Note:**

All dimensions are nominal.  
 To prevent zinc whiskers  
 Global IFS does not use  
 electro-galvanized finishes  
 on any of its access flooring  
 products.