



Material

Base Plate - steel, electro-galvannealed
 Tube - steel, 7/8" square hot dipped galvanized
 Pedestal axial load test per Cisca recommended testing
 procedures for access flooring.

Note:

All dimensions are nominal.
 To prevent zinc whiskers
 Global IFS does not use
 electro-galvanized finishes
 on any of its access flooring
 products.